

DISTRICT WATER TESTING LABORATORY, JALANDHAR

Water Supply and Sanitation Office, Near Bara Dari, Near DC Office, Jalandhar
dwtljalandhar@gmail.com

To,

St. Soldier Divine Public School, Bir Pind.
Distt. Jalandhar


No.: DWTJAL/2425/00242 Dated : 07/09/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SSPPS/GEN/SP-1 Dated: 02/09/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 05/09/2024. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Jalandhar

D/A : Test Report


Authorized Signatory
For, District water Testing Laboratory
Jalandhar

DISTRICT WATER TESTING LABORATORY, JALANDHAR

Water Supply and Sanitation Office, Near Bara Dari, Near DC Office, Jalandhar

dwtljalandhar@gmail.com

TEST REPORT

Name & Address of Customer : St. Soldier Divine Public School, Bir Pind. Distt. Jalandhar		Customer Reference No.	No : SSPPS/GEN/SP 1 Dated : 02/09/2024
		Sample Submitted by	Sh. Nishkar
		Date of Sample Receipt	05/09/2024
		Analysis Starting Date	05/09/2024
		Analysis completion Date	06/09/2024
Discipline : Chemical Testing		Group: Water	
U/R No. :		Sample Type :	Water
Test Report No.:	DWTJAL/2425/00242	Date of Issue :	07/09/2024
Registration no.:	DWTJAL/REG2425/00563	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Amber Coloured Sample Bottle 500 mL.
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	St. Soldier Devine Public School, Greater Kailash, Near Railway Crossing, Bir Pind, Nurmahal Road, Nakodar.(R.O.) / NA
Village :	Birpind	Habitation :	Birpind
Block:	Nakoder	District :	Jalandhar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.94@24°C	6.5-8.5	No Relaxation	—	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	—	IS 3025 (Part 8 - 2023)
5	TDS	10.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	3.88	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	3.92	200	600	mg/l	IS 3025 (Part 21-2009)(RA 2019) EDTA Method
9	Calcium(Ca)	1.57	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium(Mg)	BDL	30	100	mg/l	APHA (24th Ed 2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	2.02	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By

Mr. Jivesh Kumar
Quality Manager



REGARDING SAFE DRINKING WATER AND SANITARY CONIDITION
CERTIFICATE

No. 658

Date: 17-09-2024

This is certified that an inspection team headed by Er. Rahis Azam Junior Engineer, from W/S & Sanitation, Sub Div. Nakodar inspected the St. Soldier Divine Public School, Vill Birpind Nakodar on 02-09-2024 and found that the St. Soldier Divine Public School, Vill Birpind Nakodar has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central/state/U.T Govt.

The above certificate is valid for a period of Six Months from the date of issue of water testing report.

Chetan Sami

Sub Divisional Engineer
W/S & Sanitation
Sub Div. Nakodar

Signature with Seal: _____

Name : Sh. Chetan Sami

Designation : Sub Divisional Engineer
Sub Division Nakodar

To

Principal

St. Soldier Divine Public School, Vill Birpind Nakodar

Note: - This department is not responsible for operation of water supply and sanitary conditions and any event/action related in future.

Office Of Senior Medical Officer

NAKODAR


CERTIFICATE

NO: 829

Date: 16/09/2024

To Whom It May Concern

Certified that the team of Health Inspectors Inspected the Premises **St. Soldier Divine Public School, Nakodar , Distt. Jalandhar** on the basis of the report given by the team, It is certified that the Health & Hygienic condition of the **St. Soldier Divine Public School, Nakodar , Distt. Jalandhar** are good at present.


Senior Medical Officer

Senior Medical Officer
Nakodar
(i/c. Civil Hospital,
Nakodar (Jal.))

Date: 16/09/2024

Place: Nakodar